



Product Service

Attestation of Conformity

No. N8A 113943 0002 Rev. 01

Holder of Certificate: **HSA ENERJI A.S.**
OSB III. Kisim Keciliköy OSB Mah.
Mustafa Kemal Bulvari No:15
45030 Yunusemre - Manisa
TÜRKIYE

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062144401-01

Date, 2022-08-17

(David Bo)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 113943 0002 Rev. 01

Model(s):

HSA72M10MF-xxxW, xxx = 530 to 560 in steps of 5
HSA66M10MF-xxxW, xxx = 485 to 510 in steps of 5
HSA60M10MF-xxxW, xxx = 445 to 465 in steps of 5
HSA54M10MF-xxxW, xxx = 400 to 420 in steps of 5
xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06